



Bio Services cc

TEL: 011 794 1509 FAX: 011 794 2592 E MAIL: bios@hixnet.co.za
UNIT 15, LASER SQUARE, 123 ZEISS RD, HONEYDEW EXT 5 LASER PARK
REG No CK86/09164/23
PO BOX 4240, RANDBURG, 2125
ESTABLISHED SINCE 1986

CERTIFICATE OF ANALYSIS

DATE: 14.11.13

DATE RECEIVED: 08.11.13

CLIENT NAME: CENTURION BIO DIESEL

ATTENTION: MIRON / DEON

REFERENCE: BIO DIESEL SAMPLE

ANALYSIS	SPECIFICATION SANS 1935:2004	SAMPLE
APPEARANCE		CLEAR
DENSITY @ 15°C kg/l	0.860-0.900	0.8830 PASS
VISCOSITY @ 40°C	3.5-5.5	5.09 PASS
FLASH POINT °C	120 MIN	174
WATER CONTENT%	0.05 MAX	0.04 PASS
ACID VALUE mg KOH/g	0.5 MAX	0.35 PASS
FREE GLYCEROL%	0.02 MAX	0.01 PASS
TOTAL GLYCEROL%	0.25 MAX	0.25 PASS

COMMENTS:

Sample conforms to the specification where tested.

CHECKED AND COMPILED BY: Mark Finnegan



This document is not intended to relieve the parties involved of any contractual obligations and may not be used in litigation. All analysis carried out with due care and skill. Liability shall not exceed the fee or commission paid for the service detailed in the document and will only be considered if gross negligence is proven.